



CERTIFICATE OF CONFORMITY TOUGHENED SAFETY GLASS

BS EN 12150: GLASS IN BUILDING THERMALLY TOUGHENED SODA LIME SILICATE SAFETY GLASS

THIS CERTIFICATE OF CONFORMITY CONFIRMS THAT THE PRODUCTS SUPPLIED BY THE COMPANY BELOW CONFORMS TO
CPR 305/2011 AND WITH EN 12150-2 ANNEX ZA

UKCA MARK DECLARATION YEAR: 2025



Victorian House, Parc Hendre, Capel Hendre, Ammanford, SA18 3FA

TEST LABORATORY	TEST STANDARD	GLASS SPECIFICATION	TEST REPORT NUMBER	CLASSIFICATION
Wintech Engineering	12150: FRAGMENTATION	CLEAR FLOAT	R13098-3	PASS
		PLANITHERM SOFT COAT	R13098-2	PASS
		OBSCURE (STIPPOLYTE)	R13098	PASS
Wintech Engineering	12600: PENDULUM IMPACT	CLEAR FLOAT	R13097-2	1 (C) 1
		PLANITHERM SOFT COAT	R13097	1 (C) 1
		OBSCURE (STIPPOLYTE)	R13097-3	1 (C) 1
Wintech Engineering	EN 1288: FOUR POINT BEND TEST	CLEAR FLOAT	R13099-1	PASS
		PLANITHERM SOFT COAT	R13099	PASS

(a) SUBMITTING GLASS FOR INITIAL TYPE TESTING TO EN 12150, EN12600 AND SUCCESSFULLY MEETING ALL REQUIREMENTS.

(b) INSTIGATING AND IMPLEMENTING A SYSTEM OF FACTORY PRODUCTION CONTROL COMPLYING WITH BS EN 12150-2:2004

(c) PRODUCING A TECHNICAL FILE CONTAINING THE TEST REPORT AND PERFORMANCE INDICATION PAPERS FOR ALL COMPONENTS

Signed By Jason Powell

jason powell

Date:

19/12/2025

Position: Production Director